



**FLAMMABILITY TEST CERTIFICATE – SURFACE IGNITION:**  
**BS 5867-2: 2008 Type “B”.**

Test method:

BS EN ISO 15025: 2002 Procedure A (Surface ignition).

Date : 27<sup>th</sup> September 2022.  
 Client Ref. : 100% Polyester (Pink).  
 Client : Stage Electrics Partnerships Ltd. (Flamecheck Plus).  
 Address : Encore House, Unit 3, Britannia Road, Patchway Trading Estate,  
 Patchway, Bristol, BS34 5TA.  
 Date Recd. : 20<sup>th</sup> September 2022.  
 Test Date. : 26<sup>th</sup> September 2022.  
 Order Number : 389046 (Payment with order).  
 Quotation Number : Q229903.  
 Pre-treatment : Unnecessary, (Clients request).  
 Conditioning : 24 Hrs at 20±2 °C and 65±5%RH.  
 Flame application : 15 seconds using Propane gas.  
 Deviation to Standard : None.

This certificate relates only to the material supplied and tested.

Tested on face of fabric	Fabric Warp direction				Fabric Weft direction			
	1↕	2↕	3↕	4↕	1↔	2↔	3↔	4↔
Specimen number								
Flame reached an edge (√ or x)	x	x	x	n/a	x	x	x	n/a
Hole reached an edge (√ or x)	x	x	x	n/a	x	x	x	n/a
Flaming debris (√ or x)	x	x	x	n/a	x	x	x	n/a

√ = Yes, X = No,

All six specimens comply with the requirements; therefore, the fabric shall be deemed to conform to the requirements of BS 5867-2: 2008 6.3 type “B”.

In accordance with the requirements of BS 5867-2 the fabric should be labelled  
**“IF WETTED IN ANY WAY IT IS ESSENTIAL TO RE-TREAT THE FABRIC TO MEET  
 FLAMMABILITY REQUIREMENTS”.**

End of Certificate.

Signature:

K. D. James

Technical Manager, For and on behalf of J.C.S. Technology Ltd.

**Quality Management System Approved to ISO 9001:2015**

Advanced Certification UKAS number 8872

Form Number: 24.1(5) Issue 7

JCS Technology Ltd. Registered Office: Unit 8, B.W. Estate, Oldmixon Crescent,  
 Weston-super-Mare. BS24 9BA. Tel +44 (0)1934 644866. E-mail : [Ken@jcs-tech.co.uk](mailto:Ken@jcs-tech.co.uk).

Company No. 9474956 - Registered in England and Wales.

Director: K. D. James.